CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 3725-0684:103 Page 1 of 1

CATEGORY: Door Hardware-Fire Rated

LISTEE: Adams Rite Mfg, *260 Santa Fe St., Pomona, CA 91767

Contact: Misak Panossian (909) 632-2300

DESIGN: Series 3100 and 3100T surface mount vertical rod and Series 3300 mortise type fire exit

> devices. Series 3100 consists of concealed vertical rods, actuated top and bottom bolts, and a push bar assembly. Series 3100T consists of concealed vertical rod, actuated at the top only and a push bar assembly. Series 3300 consists of a single point mortise latch and a

push bar assembly.

The maximum size of a single door is 4' wide x 8' high and a pair of doors is 8' wide x 8'

high.

Refer to listee's data sheet for detailed product description and operational considerations.

RATING: Series 3100 and 3300: suitable for 3/4, 1-1/2, and 3 Hr. metal fire doors

Series 3100T: suitable for 3/4 & 1-1/2 Hr. metal fire doors and 20 min. plastic and wood fire

doors

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating and UL label.

APPROVAL: Listed as fire exit hardware for use on pairs or double egress pairs of swinging fire-rated

doors except Model 3300 single point mortise type is intended for use with single door only.

NOTE: Formerly 3725-0684:103 and 4140-0684:103

*Rev. 07-26-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

JUNE 15, 2003 Date Issued: Listing Expires June 30, 2004

DIANE K. AREND, Senior Deputy Authorized By:

Program Manager